


Texas Commission on Environmental Quality

CERTIFICATE OF DELIVERY OF PUBLIC NOTICE TO CUSTOMERS: Boil Water Notice

Public Water System (PWS) name:	CITY OF WELLS
PWS ID: <u>0370004</u> Date of viol	ation(s) or situation(s) December 23, 2022
Type of Total Coliform Rule Ground	Water Rule violation(s) or situation:
condition requiring a BW	due to: loss of pressure, line break, water outage, or any N (includes Rescind Notice) tion (Ground Water or Surface Water Treatment Rule)
	or PWS make an adequate, good-faith effort to reach all opropriate methods (check all below that apply):
COMMUNITY WATER SYSTEM	(perform one of the following):
the area surrounding the p Publish BWN in local new Deliver BWN directly to e	
NONCOMMUNITY WATER SYST	ΓΕΜ (perform one of the following):
Deliver BWN directly to c Post BWN in public places	ustomers, or swithin the area served by the system
direction or supervision in accordance properly gather and evaluate the infor- persons who manage the system, or the information, the information submitted	s document and all attachments were prepared under my with a system designed to assure that qualified personnel mation submitted. Based on my inquiry of the person or ose persons directly responsible for gathering the d is, to the best of my knowledge and belief, true, accurate re significant penalties for submitting false information, mprisonment for knowing violations."
Certified by: (print name): Carl Pe	ennington/Roy Shanks Title: Superintendent
Date of Delivery to Customers:1	2/23/2022 Phone: (936) 867-4615
Signature: Qui	Date: 2/23/22
Fax to (512) 239-3666 or mail a copy Notices given to your customers to: Attn: Public Notice. P. O. Box 1308 Revised 01/18/2012	y of this completed form, <u>AND</u> copies of the Public TCEQ – Public Drinking Water Section MC – 155, 7 Austin, TX 78711-3087



Public Notice to Boil Water

December 23, 2022

Due to <u>THE ELEVATED TANK FREEZING, CAUSING CITY WIDE OUTAGE</u>, the Texas Commission on Environmental Quality (TCEQ) has required our water system for the CITY OF WELLS

ID# 0370004 to notify customers of the need to boil their water before consumption.

The only structures effective by this water line break are listed below:

All Customers on the City of Wells Utility System

To ensure the destruction of all harmful bacteria and other microbes, water for drinking, cooking, and making ice should be boiled and cooled before use. The water should be brought to a vigorous, rolling boil and then boiled for two minutes. In lieu of boiling, you may purchase bottled water or obtain water from some other suitable source.

When it is no longer necessary to boil the water, the water system officials will notify you that the water is safe for consumption. Instructions to discontinue boiling will be issued in the same manner as this notice.

If you have questions concerning this matter, you may contact Operator: Roy Shanks (936) 212-3220 or City hall at (936) 867-4615

If a customer wishes to contact the TCEQ, they may call 512-239-4691.

City of Wells

From:

City of Wells <no-reply@municipalimpact.com>

Sent:

Friday, December 23, 2022 9:06 AM

To:

city of wells @consolidated.net

Subject:

Alert from City of Wells

Importance:

High

Alert from City of Wells: Boil Water Notice for All Customers

Date: Dec 23, 2022

Click the link for the entire message:

Public Notice to Boil Water Effective December 23, 2022

Due to extreme temperatures causing the elevated storage tank to freeze, causing an interruption in some services, the Texas Commission on Environmental Quality (TCEQ) has required our water system, CITY OF WELLS ID# 0370004, to notify customers of the need to boil their water before consumption.

This notice is for all customers on the City of Wells Water Service.

To ensure the destruction of all harmful bacteria and other microbes, water for drinking, cooking, and making ice should be boiled and cooled before use. The water should be brought to a vigorous, rolling boil and then boiled for two minutes. In lieu of boiling, you may purchase bottled water or obtain water from some other suitable source.

When it is no longer necessary to boil the water, the water system officials will notify you that the water is safe for consumption. Instructions to discontinue boiling will be issued in the same manner as this notice.

If you have questions concerning this matter, you may contact Operator: Roy Shanks (936) 212-3220 or City hall staff at (430) 244-9247.

If a customer wishes to contact the TCEQ, they may call 512-239-4691.

To unsubscribe: https://cityofwells.us/unsubscribe.html?i=20037&e=cityofwells@consolidated.net .

Special Precautions Log 123/2

affected by the event (such as highest elevation): If no, record the PSI at the worst case location(s)

Initials hitials Initials PS 2 67 Homey Location Location

Location of event(s):

4702e Cilthing Water Off Locations of flushing and disinfectant Inleter tower - tower

See thush sheet

residual results:

Locations of bacteriological samples:

See labs

notice, and other applicable documentation. Attach BWM, Certificate of Public Delivery, bacteriological lab samples, BWN rescind

Note 1: If a line break area was contaminated does not utilize slug chlorination, then a BWN (e.g. sewer main break near it), and system should be issued

Did the water main pressure drop below 20 PSI and was the line partially or fully dewatered? Option

Circle Yes or No and Initial Each Answer A. Can the mains be disinfected according to AWWA Standards (C651-05) & flushed?

BWW N/A

1. Was the trench treated with calcium hypochlorite?

BWN W/A

2. Were couplings swabbed with sodium hypochlorite?

BWN V/A Initials

3. If slug chlorination is planned, where practical, then:

If No, then skip No. 3, but see Note 1 KA 3.1 Can service connections be shut off? 3.2 Can the main(s) be isolated? Initials

but see Note 1. NA If No, then skip No. 3, Yes

3.3 Before slugging, review 4.7 of C651-05. Then list:

regarding disposal of heavily chlorinated water. Contact Time Initials 3.4 If slugged, then see Appendix C of C651-05 Cl2 Concentration

4. Were the main(s) flushed until water was clear? BWN Initials Were the disinfectant residuals restored to normal? (List locations and results in notes section.) BWN nitials

BWN 6. Were bacteriological samples taken? Š Yes

customers in the area where the loss of pressure B. Issue a Boil Water Notice (BWN) to the

perator Signature

Examples: Door Hanger, Radio, TV, Signs, Call System 1. List BWN method of delivery? Mass Coul occurred.

2. Is BWN notice attached? (Yes) No

Method(s)

Initials

nitials

Delivery & BWN faxed to TCE 3. Was Certificate of Public

Though not required, (Yes) No were lines flushed (recommended)? 4. Though not required,

nitials

3

Yes No 5. Were bacteriological samples taken?

nitials

(List locations and results in notes section.) Yes expedite results (fax)? Was lab asked to

Initials effect and TCEQ contacted? Yes 7. Were Backerologicals negative: 7.1 Was BWN left in

rescind notice issued? notice faxed to TCEQ? results and rescind 7.2.1 Were lab ▼ 7.2 Was a BWN

Initials

http://www.tceq.texas.gov/drinkingwater/microbial/ For further instructions and forms, see: notices/boilwater.html

11:504 10 40 77 ON 10 Date (2.23-22 Date: 12.28.22 2 SY10576 B $\stackrel{\mathcal{Z}}{>}$ ō の子の Laboratory Sample ID 0820 88 (CS+) T104704316 TCEQ Laboratory ID: (1) けら 450 なら はら Date & Time いれないない TIME: Time, ر ا AZL AZL 22 Date: 12-28-20 Date: 72-22 N Date / Pme: П Present EASTEX EMPOSTMENT LIGHT Test Results must meet all occreditation / certification requirements unless stated otherwise. SHADED AREA FOR LABORATORY USE DNLY Jate / Time: Jate/ Time: П П E Coli Absent P H E M E B B Absent Present Lab Results Total Coliform *Special and Contraction samples are NOT FOR COMPLIANCE | Lab Rejected Code (LR) - Document Reason: SM 9223E Eastex Environmental Laboratory, Inc. - Nacogdoches Nacogdoches, TX 75981 Fax: 936-569-8951 国 国 囝 e B 图 国 国 eceived By (Courier, if applicable); Prèsent 100 П Chioring ~ head By (Sampler) Refinquished By (Counter): Method: www.eastexlabs.com Quito. Absent | 图 图 Ø e 闰 E P 图 Rejection Code (if applicable) -Resultmil Please Ğ 1119 S. University Drive Phone: 936-569-8879 3 9 ر مو س Competing Temps aboratory Approval: Temperature Circle Thir for Free, Third Total. 10-PI @ H @ H @ H B H L L L L L Sample load Ø. 0-Report to Client By Chlorine Residua ab Comments: (mg/L) 20 Tested By: 0 () Sample ID & Date of Orlighreting Sample (All Repeat. Replacement. & Triggered Raw Samples) | LOwner | LOperator | Uther. | Log 2 H | Log 2 H | Log 2 H | Lower | Lower | Logerator | Logerator | Lower | Logerator | Lower | TCEQ Form 10525 08/2017 Water System Identification & Sample Collection Information (Please type or use block print) зерівсетепі Ø E (6) E (g) E (g) E £ £ N E Please circle All or PM 関係の言れて 22/10:54 S. S. Time 17.25EX 24 11. P. 24 6:JE 2724/1/1/2 14 50 W 图 Operator Collected 75976 TCEQ Microbial Reporting Form N **ЈВӨ**Д K 2 2 2 A YEQ Owner Form instructions: www.tosq.fexas.gov/chinkingwater/microbial/revisec-total-coliform-rule Zip Code: d O. Signature: -N 100 Моліћ <u>o</u> N Other Contact (v one) Construction L × A. , pecial eg/i yh. 4 0370004 Sample Type: HBW W65 Jeede/ (noiluditaiO のできるの eugnoy Use Specific Address / Location identified in Sample NIWERCHOW げのグル なるが、個 120 July 150. Toves だるのの 产 Raw Wells - Use Source ID for Well Sampled (Example G1234567A) City of Wells Cherokee (936) 867-4615 Sample Identification/Location City of Wells Public Water System ID: PO Box 20 SECREPAND SOL Parak Aver 000 A St 22 Worren Rd なみであれている。 のでは \ \ \ \$ \$\frac{1}{2}\$\$ \$\frac{1}{2}\$\$ Wells County: Public Wafer System Name: X E S Sampler Name (Print) Derator License #. Phone # Name: Gir State: \ \ \ \ \ Address: 337 TA <u>~</u> 20 120 8 0 Report Results To:

٠	Finish Residual	7,4	3.	3,4	2.9	3.2	3.1	2.8	2,9	2,9	3.3
BOIL WATER NOTICE	Start Residual	1.9	2.1	2,0	1,5	2,0	1.3	1, 1	2.0	1,8	2.1
	Date	12/24/22	12/24/22	12/24/22	12/24/22	12/24/21	12/24/22	12/24/22	12/24/22	12/24/22	12/24/22
720	Flush Time	20 mba	15 mh	25 min	20 mia	15 min	30 m." n	30min	15 m sh	25 min	1000
NOTICE 12/23/2022	LOCATION	N69577	569 55	8306 FM 1247	446 Homer Rd	38 Warner	3846 C.R.2631	1920 CR. 2631	2336 HWY 69 N	1-1001 69 N	258 4th St
SPECIAL FLUSHING FOR BOIL WATER NOTICE	CUSTOMER NAME	USGG N. Traner	Yarbrough	Purveas	hose mary Moore	byenen Shemness	Hicks Pasture	1/5a Ford	Bruce Spurgen	Wallace,	Carty Williams



Cancelled Notice

On **December 23, 222**, the Texas Commission on Environmental Quality (TCEQ) required our public water system, **CITY OF WELLS ID# 0370004**, to issue a Boil Water Notice (BWN) to inform our customers that due to the elevated tank freezing causing a city-wide interruption in service, water from our system must be boiled prior to consumption.

Location: All customers on the City of Wells Utility System,

Our system has taken the necessary corrective actions to restore adequate pressure, disinfectant levels, and bacteriological quality and has provided TCEQ with testing results that indicate that the water no longer requires boiling as of **December 29**, 2022.

f you have questions concerning this matter, you may contact Roy Shanks, Operator, or City hall at (936) 867-4615.

If a customer wishes to contact the TCEQ, they may call. (512) 239-4691

City of Wells

From:

City of Wells <no-reply@municipalimpact.com>

Sent:

Thursday, December 29, 2022 5:08 PM

To:

cityofwells@consolidated.net

Subject:

Alert from City of Wells

Importance:

High

Alert from City of Wells: Boil Water Rescind Notice

Date: Dec 29, 2022

Click the link for the full message Boil Water Rescind Notice

On Decwmbwr 23, 2022, the Texas Commission on Environmental Quality (TCEQ) required our public water system CITY OF WELLS ID# 0370004 to issue a Boil Water Notice (BWN) to inform our customers that due to the elevated tank freezing causing an interruption in service, water from our system must be boiled prior to consumption.

Our system has taken the necessary corrective actions to restore adequate pressure, disinfectant levels, and/or bacteriological quality and has provided TCEQ with testing results that indicate that the water no longer requires boiling as of December 29, 2022.

If you have questions concerning this matter, you may contact Roy Shanks or Melanie Pounds at (936) 867-4615.

If a customer wishes to contact the TCEQ, they may call (512) 239-4691

To unsubscribe: https://cityofwells.us/unsubscribe.html?i=20037&e=cityofwells@consolidated.net .